

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0065:003 Page 1 of 1

**CATEGORY:** Audible Signal Devices

**LISTEE:** Faraday Inc, 805 South Maumee St., Tecumseh MI 49286  
Contact: Steve A. Blohm (517) 423-2111

**DESIGN:** Models 3410, 3420, 3470, 3620, 3670, 3820, 3920, 4070, 4410, 4420, 4450, 4480 and 4770 single-stroke bells. The last digit of the model number "0" (no gong or chime) can be replaced with a number 1 (10" gong), 4 (4" gong), 5 (chime), 6 (6" gong) or 8 (8" gong). Separately listed compatible strobes may be used with these devices. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name or registered trademark "FOS", catalog number, electrical rating and UL label.

**APPROVAL:** Listed as audible devices for use with separately listed compatible control units.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Corrected 01-30-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager